



Winthrop University
Police Department

Daily Fire Log

Month of February, 2024



Incident #: N/A	
Date Reported: 02/02/2024	Time Reported: 2:10 AM
Date(s) Occurred: 02/02/2024	Time(s) Occurred: 2:10 AM
Location: Lee Wicker Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded to room 210 in reference to a fire alarm being activated. There was no fire or smoke and the alarm was reset.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 02/02/2024	Time Reported: 7:05 PM
Date(s) Occurred: 02/02/2024	Time(s) Occurred: 7:05 PM
Location: Lee Wicker Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm being activated. There was no sign of smoke or fire and the alarm was set off by a hair straightener. The alarm was reset.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 02/04/2024	Time Reported: 10:35 PM
Date(s) Occurred: 02/04/2024	Time(s) Occurred: 10:35 PM
Location: Lee Wicker Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm being activated. There was no smoke or fire and the alarm was reset.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 02/07/2024	Time Reported: 2:07 AM
Date(s) Occurred: 02/07/2024	Time(s) Occurred: 2:07 AM
Location: E. Thomson Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm being activated. The resident advised that steam from the shower set the alarm off. The alarm was reset.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 02/11/2024	Time Reported: 11:40 PM
Date(s) Occurred: 02/11/2024	Time(s) Occurred: 11:40 PM
Location: Phelps Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm being activated in the 3 rd floor kitchen. The officer observed a pot with vegetable oil in the sink. The alarm was reset.	
Disposition: Complete	



Winthrop University
Police Department



Daily Fire Log

Month of February, 2024

Incident #: N/A	
Date Reported: 02/12/2024	Time Reported: 10:47 PM
Date(s) Occurred: 02/12/2024	Time(s) Occurred: 10:47 PM
Location: W. Thomson Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded to the 3 rd floor for a fire alarm being activated. There were no signs of smoke or fire and the alarm was reset.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 02/20/2024	Time Reported: 8:41 PM
Date(s) Occurred: 02/20/2024	Time(s) Occurred: 8:41 PM
Location: W. Thomson Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm, there was no smoke or fire. The officer attempted to reset the alarm but the alarm kept turning back on. The officer contacted the FM contact and they were able to solve the issue.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 02/29/2024	Time Reported: 11:25 PM
Date(s) Occurred: 02/29/2024	Time(s) Occurred: 11:25 PM
Location: Phelps Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded and met with the resident who stated she was spraying Lysol when the smoke detector went off. The alarm was reset.	
Disposition: Complete	

Incident #:	
Date Reported:	Time Reported:
Date(s) Occurred:	Time(s) Occurred:
Location:	
Incident Type:	
Synopsis:	
Disposition:	