



**Winthrop University  
Police Department**



***Daily Fire Log***

Month of January, 2019

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 01/26/2019	<b>Time Reported:</b> 7:54 PM
<b>Date(s) Occurred:</b> 01/26/2019	<b>Time(s) Occurred:</b> 7:54 PM
<b>Location:</b> W. Thomson Hall	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> Officer responded in reference to a smoke detector that had been activated in room 359. There was no smoke or fire and the alarm was reset.	
<b>Disposition:</b> Complete	

<b>Incident #:</b>	
<b>Date Reported:</b>	<b>Time Reported:</b>
<b>Date(s) Occurred:</b>	<b>Time(s) Occurred:</b>
<b>Location:</b>	
<b>Incident Type:</b>	
<b>Synopsis:</b>	
<b>Disposition:</b>	



Winthrop University  
Police Department



Daily Fire Log

Month of February, 2019

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 02/09/2019	<b>Time Reported:</b> 11:48 PM
<b>Date(s) Occurred:</b> 02/09/2019	<b>Time(s) Occurred:</b> 11:48 PM
<b>Location:</b> Johnson Hall	
<b>Incident Type:</b> Facilities Management Request for Assistance – Alarm in Fiber Optic Office	
<b>Synopsis:</b> The officer responded in reference to the alarm going off in the fiber optic office. There was no smoke or fire. The officer had to contact FM to help reset the alarm and a work order was placed.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 02/16/2019	<b>Time Reported:</b> 9:05 AM
<b>Date(s) Occurred:</b> 02/16/2019	<b>Time(s) Occurred:</b> 9:05 AM
<b>Location:</b> Richardson Hall	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to the fire alarm being activated. The officer observed a small amount of smoke in the 4 <sup>th</sup> floor kitchen. The officer also observed a stack of pancakes and a slightly burned pan. The alarm was reset.	
<b>Disposition:</b> Complete	

<b>Incident #:</b>	
<b>Date Reported:</b>	<b>Time Reported:</b>
<b>Date(s) Occurred:</b>	<b>Time(s) Occurred:</b>
<b>Location:</b>	
<b>Incident Type:</b>	
<b>Synopsis:</b>	
<b>Disposition:</b>	



**Winthrop University  
Police Department**



**Daily Fire Log**

Month of March, 2019

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 03/02/2019	<b>Time Reported:</b> 4:07 PM
<b>Date(s) Occurred:</b> 03/02/2019	<b>Time(s) Occurred:</b> 4:07 PM
<b>Location:</b> Lee Wicker	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to a fire alarm on the second floor. The officer found a frying pan with still warm hash browns in it in the sink. The alarm was reset.	
<b>Disposition:</b> Complete	

<b>Incident #:</b>	
<b>Date Reported:</b>	<b>Time Reported:</b>
<b>Date(s) Occurred:</b>	<b>Time(s) Occurred:</b>
<b>Location:</b>	
<b>Incident Type:</b>	
<b>Synopsis:</b>	
<b>Disposition:</b>	

<b>Incident #:</b>	
<b>Date Reported:</b>	<b>Time Reported:</b>
<b>Date(s) Occurred:</b>	<b>Time(s) Occurred:</b>
<b>Location:</b>	
<b>Incident Type:</b>	
<b>Synopsis:</b>	
<b>Disposition:</b>	



**Winthrop University  
Police Department**



**Daily Fire Log**

Month of April, 2019

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 04/23/2019	<b>Time Reported:</b> 11:38 PM
<b>Date(s) Occurred:</b> 04/23/2019	<b>Time(s) Occurred:</b> 11:38 PM
<b>Location:</b> Smoking area between Rutledge and Roddey	
<b>Incident Type:</b> Other – Accidental Fire	
<b>Synopsis:</b> While providing an escort the officer observed smoke coming from the smoking can. The officer removed the lid and saturated the smoke. There was no damage.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 04/25/2019	<b>Time Reported:</b> 3:30 AM
<b>Date(s) Occurred:</b> 04/25/2019	<b>Time(s) Occurred:</b> 3:30 AM
<b>Location:</b> Louse Pettus Archives and Collections	
<b>Incident Type:</b> Other – Brushfire	
<b>Synopsis:</b> The officer overheard a call from EOC in reference to a brushfire. The officer was able to put the fire out before RHFD arrived. A quick investigation determined there was an exposed electrical outlet that runs under the bush was on fire.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 04/30/2019	<b>Time Reported:</b> 2:30 PM
<b>Date(s) Occurred:</b> 04/30/2019	<b>Time(s) Occurred:</b> 2:30 PM
<b>Location:</b> Dacus Library	
<b>Incident Type:</b> Facilities Management Request for Assistance	
<b>Synopsis:</b> The officer responded in reference to a an area of mulch that was smoking and a small fire and smoke at Dacus Library. The fire has been extinguished before the officer arrived and there were no more signs of smoke or fire.	
<b>Disposition:</b> Complete	



**Winthrop University  
Police Department**

***Daily Fire Log***

Month of May, 2019



<b>Incident #:</b>	
<b>Date Reported:</b>	
<b>Time Reported:</b>	
<b>Date(s) Occurred:</b>	<b>Time(s) Occurred:</b>
<b>Location:</b>	
<b>Incident Type:</b>	
<b>Synopsis:</b>	
<b>Disposition:</b>	



**Winthrop University  
Police Department**



**Daily Fire Log**

Month of June, 2019

<b>Incident #:</b> 0619-0384	
<b>Date Reported:</b> 06/08/2019	<b>Time Reported:</b> 7:42 PM
<b>Date(s) Occurred:</b> 06/08/2019	<b>Time(s) Occurred:</b> 7:42 PM
<b>Location:</b> Winthrop Coliseum	
<b>Incident Type:</b> Causing Fire Alarm	
<b>Synopsis:</b> While working an OT assignment an unknown subject pulled the fire alarm. The officer observed the alarm had been activated at a pull station. After a check the alarm was reset. The subject who pulled the alarm had been escorted out prior for excessive yelling.	
<b>Disposition:</b> Admin. Closed	

<b>Incident #:</b>	
<b>Date Reported:</b>	<b>Time Reported:</b>
<b>Date(s) Occurred:</b>	<b>Time(s) Occurred:</b>
<b>Location:</b>	
<b>Incident Type:</b>	
<b>Synopsis:</b>	
<b>Disposition:</b>	

<b>Incident #:</b>	
<b>Date Reported:</b>	<b>Time Reported:</b>
<b>Date(s) Occurred:</b>	<b>Time(s) Occurred:</b>
<b>Location:</b>	
<b>Incident Type:</b>	
<b>Synopsis:</b>	
<b>Disposition:</b>	



**Winthrop University  
Police Department**

***Daily Fire Log***

Month of July, 2019



<b>Incident #:</b>	
<b>Date Reported:</b>	
<b>Time Reported:</b>	
<b>Date(s) Occurred:</b>	<b>Time(s) Occurred:</b>
<b>Location:</b>	
<b>Incident Type:</b>	
<b>Synopsis:</b>	
<b>Disposition:</b>	



Winthrop University  
Police Department

Daily Fire Log

Month of August, 2019



<b>Incident #:</b> N/A	
<b>Date Reported:</b> 08/17/2019	<b>Time Reported:</b> 9:53 PM
<b>Date(s) Occurred:</b> 08/17/2019	<b>Time(s) Occurred:</b> 9:53 PM
<b>Location:</b> E. Thomson Hall	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to a fire alarm. The victim stated the steam from the shower caused the alarm to sound. Everything was checked and the alarm was reset.	
<b>Disposition:</b> Complete	

<b>Incident #:</b>	
<b>Date Reported:</b>	<b>Time Reported:</b>
<b>Date(s) Occurred:</b>	<b>Time(s) Occurred:</b>
<b>Location:</b>	
<b>Incident Type:</b>	
<b>Synopsis:</b>	
<b>Disposition:</b>	





**Winthrop University  
Police Department**

**Daily Fire Log**

Month of September, 2019



<b>Incident #:</b> N/A	
<b>Date Reported:</b> 09/10/2019	<b>Time Reported:</b> 6:10 PM
<b>Date(s) Occurred:</b> 09/10/2019	<b>Time(s) Occurred:</b> 6:10 PM
<b>Location:</b> Margaret Nance Basement	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The alarm was showing activation in the basement. The officers had a hard time making entry due to custodial supplies and carts being in the way. When officers gained access there were no issues and the alarm was reset.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 09/10/2019	<b>Time Reported:</b> 8:10 PM
<b>Date(s) Occurred:</b> 09/10/2019	<b>Time(s) Occurred:</b> 8:10 PM
<b>Location:</b> Margaret Nance Hall	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded to room 216 in reference to a fire alarm being activated. The resident of the room had burnt food in the microwave. The student stated she wanted to make her room smell better so she put a honeybun in the microwave and cooked it on her for 2 minutes. The window was raised to remove the smoke and the alarm was reset.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 09/17/2019	<b>Time Reported:</b> 3:01 PM
<b>Date(s) Occurred:</b> 09/17/2019	<b>Time(s) Occurred:</b> 3:01 PM
<b>Location:</b> Winthrop Coliseum	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded to the coliseum due to a fire alarm being activated in the laundry room. The officer could detect the odor of smoke. The clothes were removed from the dryer and the lint was cleaned out. At no time was there any flames.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 09/23/2019	<b>Time Reported:</b> 12:58 PM
<b>Date(s) Occurred:</b> 09/23/2019	<b>Time(s) Occurred:</b> 12:58 PM
<b>Location:</b> Margaret Nance Hall	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to an alarm activation that occurred in the basement. It was determined to be a malfunction and FM advised they would replace it.	
<b>Disposition:</b> Complete	

<b>Incident #:</b>	
<b>Date Reported:</b>	<b>Time Reported:</b>
<b>Date(s) Occurred:</b>	<b>Time(s) Occurred:</b>
<b>Location:</b>	
<b>Incident Type:</b>	
<b>Synopsis:</b>	
<b>Disposition:</b>	



**Winthrop University  
Police Department**

***Daily Fire Log***

Month of October, 2019



<b>Incident #:</b>	
<b>Date Reported:</b>	<b>Time Reported:</b>
<b>Date(s) Occurred:</b>	<b>Time(s) Occurred:</b>
<b>Location:</b>	
<b>Incident Type:</b>	
<b>Synopsis:</b>	
<b>Disposition:</b>	



**Winthrop University  
Police Department**

**Daily Fire Log**

Month of November, 2019



<b>Incident #:</b> N/A	
<b>Date Reported:</b> 11/05/2019	<b>Time Reported:</b> 4:43 AM
<b>Date(s) Occurred:</b> 11/05/2019	<b>Time(s) Occurred:</b> 4:43 AM
<b>Location:</b> The Courtyard	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to an alarm. The officer observed water leaking from what appeared to be a sprinkler pipe. FM was contacted and responded to check the problem.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 11/13/2019	<b>Time Reported:</b> 9:47 PM
<b>Date(s) Occurred:</b> 11/13/2019	<b>Time(s) Occurred:</b> 9:47 PM
<b>Location:</b> Margaret Nance Hall	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to a fire alarm outside the kitchen area on the 2 <sup>nd</sup> floor. The officer observed a frying pan on the stove with grease in it. It also appeared the grease may have been burnt. The alarm was reset.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 11/13/2019	<b>Time Reported:</b> 10:40 PM
<b>Date(s) Occurred:</b> 11/13/2019	<b>Time(s) Occurred:</b> 10:40 PM
<b>Location:</b> Rutledge – Patio Area	
<b>Incident Type:</b> Other – Accidental Fire	
<b>Synopsis:</b> The officer responded in reference to a fire. The officer made contact with the accused who stated she was working on an art project and was scorching it when the project caught fire and was a total loss. Two fire extinguishers were used to put the fire out.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 11/15/2019	<b>Time Reported:</b> 4:02 AM
<b>Date(s) Occurred:</b> 11/15/2019	<b>Time(s) Occurred:</b> 4:02 AM
<b>Location:</b> The Courtyard	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to a fire alarm activation due to a water flow sensor in the sprinkler system. FM responded and stated they would fix the problem and the alarm was reset.	
<b>Disposition:</b> Complete	

<b>Incident #:</b>	
<b>Date Reported:</b>	<b>Time Reported:</b>
<b>Date(s) Occurred:</b>	<b>Time(s) Occurred:</b>
<b>Location:</b>	
<b>Incident Type:</b>	
<b>Synopsis:</b>	
<b>Disposition:</b>	



**Winthrop University  
Police Department**



**Daily Fire Log**

Month of December, 2019

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 12/07/2019	<b>Time Reported:</b> 10:01 PM
<b>Date(s) Occurred:</b> 12/07/2019	<b>Time(s) Occurred:</b> 10:01 PM
<b>Location:</b> Margaret Nance Hall	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to a fire alarm in room 310 being set off. The student stated her hairdryer set the alarm off. The alarm was reset.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 12/08/2019	<b>Time Reported:</b> 4:15 PM
<b>Date(s) Occurred:</b> 12/08/2019	<b>Time(s) Occurred:</b> 4:15 PM
<b>Location:</b> 2000 Winthrop Alumni Dr.	
<b>Incident Type:</b> Other – Vehicle Fire	
<b>Synopsis:</b> The officer responded to the West Center in reference to smoke coming from a vehicle that was parked there. RHFDD responded and put the fire out.	
<b>Disposition:</b> Complete	

<b>Incident #:</b>	
<b>Date Reported:</b>	<b>Time Reported:</b>
<b>Date(s) Occurred:</b>	<b>Time(s) Occurred:</b>
<b>Location:</b>	
<b>Incident Type:</b>	
<b>Synopsis:</b>	
<b>Disposition:</b>	