



**Winthrop University  
Police Department**

**Daily Fire Log**

Month of January, 2022



<b>Incident #:</b> N/A	
<b>Date Reported:</b> 01/10/2022	<b>Time Reported:</b> 7:42 AM
<b>Date(s) Occurred:</b> 01/10/2022	<b>Time(s) Occurred:</b> 7:42 AM
<b>Location:</b> Fire Alarm Activation	
<b>Incident Type:</b> Margaret Nance Hall	
<b>Synopsis:</b> The officer responded to room 221 in reference to an alarm and met with the resident who stated she had been brewing a cup of coffee when the alarm went off. The alarm was reset	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 01/13/2022	<b>Time Reported:</b> 6:08 PM
<b>Date(s) Occurred:</b> 01/13/2022	<b>Time(s) Occurred:</b> 6:08 PM
<b>Location:</b> Margaret Nance Hall	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to a fire alarm coming from room 219. The officer noticed a smell of food but no smoke or fire. The alarm was reset.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 01/22/2022	<b>Time Reported:</b> 1:08 AM
<b>Date(s) Occurred:</b> 01/22/2022	<b>Time(s) Occurred:</b> 1:08 AM
<b>Location:</b> Margaret Nance Hall	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to a fire alarm being activated. There was no sign of fire or smoke. The alarm was reset.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> 0122-1881	
<b>Date Reported:</b> 01/24/2022	<b>Time Reported:</b> 11:36 PM
<b>Date(s) Occurred:</b> 01/24/2022	<b>Time(s) Occurred:</b> 11:36 PM
<b>Location:</b> The Courtyard	
<b>Incident Type:</b> Fire Investigation	
<b>Synopsis:</b> The officer responded in reference to a fire in room 112 that appeared to have started in the dryer. The officer used a fire extinguisher until RHFD arrived and put the fire out and cleared the room of smoke.	
<b>Disposition:</b> Active	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 01/28/2022	<b>Time Reported:</b> 4:06 PM
<b>Date(s) Occurred:</b> 01/28/2022	<b>Time(s) Occurred:</b> 4:06 PM
<b>Location:</b> Roddey Apartments	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to a fire alarm coming from the third floor. The officer checked the area and there was no smoke or fire and the alarm was reset.	
<b>Disposition:</b> Complete	



**Winthrop University  
Police Department**

***Daily Fire Log***

Month of January, 2022



<b>Incident #:</b>	
<b>Date Reported:</b>	<b>Time Reported:</b>
<b>Date(s) Occurred:</b>	<b>Time(s) Occurred:</b>
<b>Location:</b>	
<b>Incident Type:</b>	
<b>Synopsis:</b>	
<b>Disposition:</b>	



**Winthrop University  
Police Department**

**Daily Fire Log**

Month of February, 2022



<b>Incident #:</b> N/A	
<b>Date Reported:</b> 02/02/2022	<b>Time Reported:</b> 12:11 PM
<b>Date(s) Occurred:</b> 02/02/2022	<b>Time(s) Occurred:</b> 12:11 PM
<b>Location:</b> W. Thomson Hall	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officers responded in reference to a fire alarm being activated. The officer made contact with the victim who stated the alarm went off while he was sleeping. There was no smoke or fire and the alarm was reset.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 02/18/2022	<b>Time Reported:</b> 12:43 AM
<b>Date(s) Occurred:</b> 02/18/2022	<b>Time(s) Occurred:</b> 12:43 AM
<b>Location:</b> Margaret Nance Hall	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to a fire alarm in a room on the 2 <sup>nd</sup> floor. There was no sign of smoke and the alarm was reset.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 02/21/2022	<b>Time Reported:</b> 1:30 PM
<b>Date(s) Occurred:</b> 02/21/2022	<b>Time(s) Occurred:</b> 1:30 PM
<b>Location:</b> Phelps Hall	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to a fire alarm but there was no smoke or fire observed. The alarm was reset. FM stated it was dust that had gotten into the alarm.	
<b>Disposition:</b> Cpmplete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 02/23/2022	<b>Time Reported:</b> 11:53 AM
<b>Date(s) Occurred:</b> 02/23/2022	<b>Time(s) Occurred:</b> 11:53 AM
<b>Location:</b> Macfeat House	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to the alarm. There was no fire, the alarm went off due to oil used for cooking. The alarm was reset.	
<b>Disposition:</b> Complete	

<b>Incident #:</b>	
<b>Date Reported:</b>	<b>Time Reported:</b>
<b>Date(s) Occurred:</b>	<b>Time(s) Occurred:</b>
<b>Location:</b>	
<b>Incident Type:</b>	
<b>Synopsis:</b>	
<b>Disposition:</b>	



**Winthrop University  
Police Department**

**Daily Fire Log**

Month of March, 2022



<b>Incident #:</b> N/A	
<b>Date Reported:</b> 03/06/2022	<b>Time Reported:</b> 12:52 AM
<b>Date(s) Occurred:</b> 03/06/2022	<b>Time(s) Occurred:</b> 12:52 AM
<b>Location:</b> Phelps Hall	
<b>Incident Type:</b> Assist Other Agency	
<b>Synopsis:</b> The officer responded to the area of Cherry & Park Ave. to provide assistance in regards to a vehicle fire. There was no fire a parked vehicle had parked over the steam pipe.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 03/16/2022	<b>Time Reported:</b> 3:23 PM
<b>Date(s) Occurred:</b> 03/15/2022	<b>Time(s) Occurred:</b> 3:23 PM
<b>Location:</b> McLaurin Hall	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to an alarm showing a water flow activation. The officer looked for a possible fire and sprinkler activation but was unable to locate anything and the alarm was reset,.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 03/20/2022	<b>Time Reported:</b> 9:12 PM
<b>Date(s) Occurred:</b> 03/20/2022	<b>Time(s) Occurred:</b> 9:12 PM
<b>Location:</b> 891 Ebenezer Ave.	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to a fire alarm. The officer met with the subject who stated he was cooking food and it burnt, there was no fire and the alarm was reset.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 03/24/2022	<b>Time Reported:</b> 5:31 PM
<b>Date(s) Occurred:</b> 03/24/2022	<b>Time(s) Occurred:</b> 5:31 PM
<b>Location:</b> Phelps Hall	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to a fire alarm. The alarm was caused due to a cooking incident and was reset.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 03/26/2022	<b>Time Reported:</b> 2:41 PM
<b>Date(s) Occurred:</b> 03/26/2022	<b>Time(s) Occurred:</b> 2:41 PM
<b>Location:</b> Richardson Hall	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded to the kitchen area of the 6 <sup>th</sup> floor in reference to burnt food that caused the fire alarm to go off. The alarm was reset.	
<b>Disposition:</b> Complete	



**Winthrop University  
Police Department**

***Daily Fire Log***

Month of March, 2022



<b>Incident #:</b>	
<b>Date Reported:</b>	<b>Time Reported:</b>
<b>Date(s) Occurred:</b>	<b>Time(s) Occurred:</b>
<b>Location:</b>	
<b>Incident Type:</b>	
<b>Synopsis:</b>	
<b>Disposition:</b>	



**Winthrop University  
Police Department**

**Daily Fire Log**

Month of April, 2022



<b>Incident #:</b> N/A	
<b>Date Reported:</b> 04/01/2022	<b>Time Reported:</b> 3:56 PM
<b>Date(s) Occurred:</b> 04/01/2022	<b>Time(s) Occurred:</b> 3:56 PM
<b>Location:</b> Margaret Nance Hall	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to a smoke alarm being activated. The subject stated when she opened her window is when the alarm went off. The alarm was reset.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 04/05/2022	<b>Time Reported:</b> 7:02 PM
<b>Date(s) Occurred:</b> 04/05/2022	<b>Time(s) Occurred:</b> 7:02 PM
<b>Location:</b> Lee Wicker Hall	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to the fire alarm being activated. The officer did observe burnt food in the kitchen on the stove top. The alarm was reset.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 04/11/2022	<b>Time Reported:</b> 10:19 PM
<b>Date(s) Occurred:</b> 04/11/2022	<b>Time(s) Occurred:</b> 10:19 PM
<b>Location:</b> Richardson Hall	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to the alarm which was determined just to be steam. The alarm was reset.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 04/13/2022	<b>Time Reported:</b> 1:36 PM
<b>Date(s) Occurred:</b> 04/13/2022	<b>Time(s) Occurred:</b> 1:36 PM
<b>Location:</b> McLaurin Hall	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to a fire alarm being activated. There alarm was for water flow. The officer did not observe any water and the alarm was reset.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 04/14/2022	<b>Time Reported:</b> 12:32 PM
<b>Date(s) Occurred:</b> 04/14/2022	<b>Time(s) Occurred:</b> 12:32 PM
<b>Location:</b> Richardson Hall	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to a fire alarm. The officer opened the door to room 105A and the room was hot and smoke was coming from the A/C unit. FM arrived on the scene to fix the problem.	
<b>Disposition:</b> Complete	



**Winthrop University  
Police Department**

**Daily Fire Log**

Month of April, 2022



<b>Incident #:</b> N/A	
<b>Date Reported:</b> 04/15/2022	<b>Time Reported:</b> 12:32 AM
<b>Date(s) Occurred:</b> 04/15/2022	<b>Time(s) Occurred:</b> 12:32 AM
<b>Location:</b> Lee Wicker Hall	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded and was advised someone had burnt food in the first floor kitchen. There was no fire and the alarm was reset.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 04/20/2022	<b>Time Reported:</b> 8:57 PM
<b>Date(s) Occurred:</b> 04/20/2022	<b>Time(s) Occurred:</b> 8:57 PM
<b>Location:</b> Rutledge Building	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to a fire alarm in the ceramics room. The professor stated they were doing an experiment when smoked filled the room. There was no fire and the alarm was reset.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 04/19/2022	<b>Time Reported:</b> 4:27 PM
<b>Date(s) Occurred:</b> 04/19/2022	<b>Time(s) Occurred:</b> 4:27 PM
<b>Location:</b> Richardson Hall	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded and observed steam coming out of the HVAC unit in room 104. FM was notified to fix the issue.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 04/21/2022	<b>Time Reported:</b> 11:09 PM
<b>Date(s) Occurred:</b> 04/21/2022	<b>Time(s) Occurred:</b> 11:09 PM
<b>Location:</b> Winthrop Coliseum	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to a fire alarm being activated. The officer met with the construction contractor who stated they were using a blower and it could have caused the alarm to go off. There was no fire and the alarm was reset.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 04/24/2022	<b>Time Reported:</b> 10:59 AM
<b>Date(s) Occurred:</b> 04/24/2022	<b>Time(s) Occurred:</b> 10:59 AM
<b>Location:</b> Withers	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded to the room where the alarm was coming from. There was no smoke or fire but the officer did observe the air unit to be blowing toward the alarm and it appeared to be dusty. The alarm was reset.	
<b>Disposition:</b> Complete	



Winthrop University  
Police Department

Daily Fire Log

Month of April, 2022



<b>Incident #:</b> N/A	
<b>Date Reported:</b> 04/24/2022	<b>Time Reported:</b> 3:08 PM
<b>Date(s) Occurred:</b> 04/24/2022	<b>Time(s) Occurred:</b> 3:08 PM
<b>Location:</b> Phelps Hall	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded to the room where the alarm was coming from and met with the subject who had left food in the microwave and forget to turn the timer off. The alarm was reset.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 04/25/2022	<b>Time Reported:</b> 7:16 AM
<b>Date(s) Occurred:</b> 04/25/2022	<b>Time(s) Occurred:</b> 7:16 AM
<b>Location:</b> Withers Building	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to a fire alarm. There was no fire and the alarm was reset.	
<b>Disposition:</b> Complete	

<b>Incident #:</b>	
<b>Date Reported:</b>	<b>Time Reported:</b>
<b>Date(s) Occurred:</b>	<b>Time(s) Occurred:</b>
<b>Location:</b>	
<b>Incident Type:</b>	
<b>Synopsis:</b>	
<b>Disposition:</b>	

<b>Incident #:</b>	
<b>Date Reported:</b>	<b>Time Reported:</b>
<b>Date(s) Occurred:</b>	<b>Time(s) Occurred:</b>
<b>Location:</b>	
<b>Incident Type:</b>	
<b>Synopsis:</b>	
<b>Disposition:</b>	





Winthrop University  
Police Department



Daily Fire Log

Month of May, 2022

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 05/01/2022	<b>Time Reported:</b> 11:01 AM
<b>Date(s) Occurred:</b> 05/01/2022	<b>Time(s) Occurred:</b> 11:01 AM
<b>Location:</b> W. Thomson Hall	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to a smoke detector in room 259. The resident advised she had just taken a hot shower and that's what caused the alarm to sound. The alarm was reset.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 05/20/2022	<b>Time Reported:</b> 9:40 PM
<b>Date(s) Occurred:</b> 05/20/2022	<b>Time(s) Occurred:</b> 9:40 PM
<b>Location:</b> Lee Wicker Hall	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to a fire alarm being activated in room 202. There was no signs of smoke or fire and the building was searched. The alarm was reset.	
<b>Disposition:</b> Complete	

<b>Incident #:</b>	
<b>Date Reported:</b>	<b>Time Reported:</b>
<b>Date(s) Occurred:</b>	<b>Time(s) Occurred:</b>
<b>Location:</b>	
<b>Incident Type:</b>	
<b>Synopsis:</b>	
<b>Disposition:</b>	

<b>Incident #:</b>	
<b>Date Reported:</b>	<b>Time Reported:</b>
<b>Date(s) Occurred:</b>	<b>Time(s) Occurred:</b>
<b>Location:</b>	
<b>Incident Type:</b>	
<b>Synopsis:</b>	
<b>Disposition:</b>	



**Winthrop University  
Police Department**

**Daily Fire Log**

Month of June, 2022



<b>Incident #:</b> N/A	
<b>Date Reported:</b> 06/14/2022	<b>Time Reported:</b> 10:27 AM
<b>Date(s) Occurred:</b> 06/14/2022	<b>Time(s) Occurred:</b> 10:27 AM
<b>Location:</b> Lee Wicker Hall	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to a fire alarm being activated. The officer went into the room and detected the odor of smoke and burnt wires coming from the microwaves. FM responded in reference to the issues. The microwaves were hot to the touch and unplugged.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 06/16/2022	<b>Time Reported:</b> 3:17 AM
<b>Date(s) Occurred:</b> 06/16/2022	<b>Time(s) Occurred:</b> 3:17 AM
<b>Location:</b> Lee Wicker Hall	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to a fire alarm in the hallway by room #149. When the officer arrived he observed water coming out of the smoke alarm in the ceiling. FM was contacted and responded to resolve the issue.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 06/23/2022	<b>Time Reported:</b> 1:44 PM
<b>Date(s) Occurred:</b> 06/23/2022	<b>Time(s) Occurred:</b> 1:44 PM
<b>Location:</b> Rutledge Hall	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to an alarm on the ground floor. There was no audible alarms going off and the officer attempted to reset the alarm but was unable to do so. FM responded to reset the alarm.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 06/28/2022	<b>Time Reported:</b> 8:19 AM
<b>Date(s) Occurred:</b> 06/28/2022	<b>Time(s) Occurred:</b> 8:19 AM
<b>Location:</b> Kinard Hall	
<b>Incident Type:</b> Other – Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to an alarm in room 116. The officer was unable to get the alarm reset and FM came to look at the alarm.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 06/28/2022	<b>Time Reported:</b> 5:45 PM
<b>Date(s) Occurred:</b> 06/28/2022	<b>Time(s) Occurred:</b> 5:45 PM
<b>Location:</b> Lee Wicker Hall	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to an alarm in room 153. The officer did observe a water leak in the hallway and FM was contacted.	
<b>Disposition:</b> Complete	



**Winthrop University  
Police Department**

***Daily Fire Log***

Month of June, 2022



<b>Incident #:/</b>	
<b>Date Reported:</b>	<b>Time Reported:</b>
<b>Date(s) Occurred:</b>	<b>Time(s) Occurred:</b>
<b>Location:</b>	
<b>Incident Type:</b>	
<b>Synopsis:</b>	
<b>Disposition:</b>	



**Winthrop University  
Police Department**

**Daily Fire Log**

Month of July, 2022



<b>Incident #:</b> N/A	
<b>Date Reported:</b> 07/01/2022	<b>Time Reported:</b> 6:59 AM
<b>Date(s) Occurred:</b> 07/01/2022	<b>Time(s) Occurred:</b> 6:59 AM
<b>Location:</b> Sykes House	
<b>Incident Type:</b> Other – Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to an alarm. The alarm was disarmed.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 07/05/2022	<b>Time Reported:</b> 10:44 AM
<b>Date(s) Occurred:</b> 07/05/2022	<b>Time(s) Occurred:</b> 10:44 AM
<b>Location:</b> W. Thomson Hall	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to a fire alarm and did not see any signs of fire or smoke. The officer attempted to reset the alarm but was unable to and FM responded to address the fire alarm.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 07/09/2022	<b>Time Reported:</b> 2:09 PM
<b>Date(s) Occurred:</b> 07/09/2022	<b>Time(s) Occurred:</b> 2:09 PM
<b>Location:</b> The Courtyard	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to a fire alarm being activated. There appeared to be a small electrical smell in the elevator room. FM responded and reset the alarm.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 07/14/2022	<b>Time Reported:</b> 12:09 PM
<b>Date(s) Occurred:</b> 07/14//2022	<b>Time(s) Occurred:</b> 12:09 PM
<b>Location:</b> West Center	
<b>Incident Type:</b> Other – Possible Trash Can Fire	
<b>Synopsis:</b> The officer responded and observed the steam grate near the trash can was emitting light smoke and an odor. FM was contacted and advised the pump for the underground system had most likely been tripped and the steam and odor was due to water burning off of an exposed pipe.	
<b>Disposition:</b> Complte	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 07/19/2022	<b>Time Reported:</b> 8:00 PM
<b>Date(s) Occurred:</b> 07/19/2022	<b>Time(s) Occurred:</b> 8:00 PM
<b>Location:</b> The Courtyard	
<b>Incident Type:</b> Fire Drill	
<b>Synopsis:</b> The officer responded in reference to a fire drill. The alarm was activated and the building was evacuated without incident. The alarm was reset.	
<b>Disposition:</b> Complete	



**Winthrop University  
Police Department**

**Daily Fire Log**

Month of July, 2022



<b>Incident #:</b> N/A	
<b>Date Reported:</b> 07/20/2022	<b>Time Reported:</b> 11:06 AM
<b>Date(s) Occurred:</b> 07/20/2022	<b>Time(s) Occurred:</b> 11:06 AM
<b>Location:</b> Winthrop Coliseum	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to a fire alarm being activated. No visible fire or smoke was seen. The alarm was activated due to work being done on the roof and FM disabled it.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 07/26/2022	<b>Time Reported:</b> 6:17 AM
<b>Date(s) Occurred:</b> 07/26/2022	<b>Time(s) Occurred:</b> 6:17 AM
<b>Location:</b> Margaret Nance Hall	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to the fire alarm being activated in room 223. Officer attempted to reset the alarm but it had a low battery and FM came to check the status.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 07/27/2022	<b>Time Reported:</b> 1:42 PM
<b>Date(s) Occurred:</b> 07/27/2022	<b>Time(s) Occurred:</b> 1:42 PM
<b>Location:</b> W. Thomson Hall	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded to W. Thomson in reference to a fire alarm. There was no fire or smoke and the alarm was reset.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 07/28/2022	<b>Time Reported:</b> 2:16 PM
<b>Date(s) Occurred:</b> 07/28/2022	<b>Time(s) Occurred:</b> 2:16 PM
<b>Location:</b> Dacus Library	
<b>Incident Type:</b> Report of Fire	
<b>Synopsis:</b> The officer was contacted by the complainant in reference to a fire that had occurred in a steam grate next to the library. The fire started due to an accumulation of leaves and disposed cigarette butts. FM cleaned the area.	
<b>Disposition:</b> Complete	



**Winthrop University  
Police Department**

**Daily Fire Log**

Month of August, 2022



<b>Incident #:</b> N/A	
<b>Date Reported:</b> 08/02/2022	<b>Time Reported:</b> 11:34 PM
<b>Date(s) Occurred:</b> 08/02/2022	<b>Time(s) Occurred:</b> 11:34 PM
<b>Location:</b> Dalton Hall	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer was flagged down about an alarm in Dalton and responded. The officer conducted a walkthrough and saw no fire or smoke. There was no alarm in dispatch. The alarm was reset.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 08/06/2022	<b>Time Reported:</b> 2:31 PM
<b>Date(s) Occurred:</b> 08/06/2022	<b>Time(s) Occurred:</b> 2:31 PM
<b>Location:</b> The Courtyard	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to a fire alarm going off in the lobby. The alarm started after the elevator had been worked on. The alarm was reset.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 08/13/2022	<b>Time Reported:</b> 4:53 AM
<b>Date(s) Occurred:</b> 08/13/2022	<b>Time(s) Occurred:</b> 4:53 AM
<b>Location:</b> The Courtyard	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to a fire alarm on the fourth floor. The officer did not observe and smoke or fire but could not get the alarm reset. FM was contacted and came and reset the alarm.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 08/16/2022	<b>Time Reported:</b> 9:19 AM
<b>Date(s) Occurred:</b> 08/16/2022	<b>Time(s) Occurred:</b> 9:19 AM
<b>Location:</b> Dalton Hall	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to a fire alarm. The officer walked through the building but did not detect any smoke or fire. The alarm was reset.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 08/22/2022	<b>Time Reported:</b> 10:37 PM
<b>Date(s) Occurred:</b> 08/22/2022	<b>Time(s) Occurred:</b> 10:37 PM
<b>Location:</b> W. Thomson Hall	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to the fire alarm being activated in room 167. The officer did not observe any signs of smoke or fire. The alarm was reset.	
<b>Disposition:</b> Complete	



**Winthrop University  
Police Department**

**Daily Fire Log**

Month of August, 2022



<b>Incident #:</b> N/A	
<b>Date Reported:</b> 08/23/2022	<b>Time Reported:</b> 10:27 PM
<b>Date(s) Occurred:</b> 08/23/2022	<b>Time(s) Occurred:</b> 10:27 PM
<b>Location:</b> Withers Building	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to fire alarm coming from the first floor west elevator lobby. There was no sign of smoke or fire. The alarm was reset.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 08/27/2022	<b>Time Reported:</b> 12:57 AM
<b>Date(s) Occurred:</b> 08/27/2022	<b>Time(s) Occurred:</b> 12:57 AM
<b>Location:</b> Margaret Nance Hall	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to a fire alarm coming from room 354. The residents stated they were sitting in their room when the alarm went off. There was no odor of smoke or fire but the room was a little humid and dusty. The alarm was reset.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 08/29/2022	<b>Time Reported:</b> 9:49 PM
<b>Date(s) Occurred:</b> 08/29/2022	<b>Time(s) Occurred:</b> 9:49 PM
<b>Location:</b> Margaret Nance Hall	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to a fire alarm being activated in room 340. The officer observed no fire. The subject stated they were heating up food and the alarm started ringing. The alarm was reset.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 08/31/2022	<b>Time Reported:</b> 10:42 AM
<b>Date(s) Occurred:</b> 08/31/2022	<b>Time(s) Occurred:</b> 10:42 AM
<b>Location:</b> Margaret Nance Hall	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to a smoke detector being activated. The officer arrived at the room and did not observe any signs of smoke or fire and the alarm was reset.	
<b>Disposition:</b> Complete	

<b>Incident #:</b>	
<b>Date Reported:</b>	<b>Time Reported:</b>
<b>Date(s) Occurred:</b>	<b>Time(s) Occurred:</b>
<b>Location:</b>	
<b>Incident Type:</b>	
<b>Synopsis:</b>	
<b>Disposition:</b>	



**Winthrop University  
Police Department**

**Daily Fire Log**

Month of September, 2022



<b>Incident #:</b> N/A	
<b>Date Reported:</b> 09/02/2022	<b>Time Reported:</b> 4:47 AM
<b>Date(s) Occurred:</b> 09/02/2022	<b>Time(s) Occurred:</b> 4:47 AM
<b>Location:</b> Rutledge Building	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to a fire alarm. The panel stated there was a leak at the sprinkler system. The officer did not observe any leaks or damage. The alarm was reset.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 09/02/2022	<b>Time Reported:</b> 5:05 AM
<b>Date(s) Occurred:</b> 09/02/2022	<b>Time(s) Occurred:</b> 5:05 AM
<b>Location:</b> Winthrop Coliseum	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> Dispatch received a call regarding a trouble alarm at the coliseum. The panel stated it was having system issues. No trouble was found and the alarm was reset.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 09/09/2022	<b>Time Reported:</b> 5:09 PM
<b>Date(s) Occurred:</b> 09/09/2022	<b>Time(s) Occurred:</b> 5:09 PM
<b>Location:</b> The Courtyard	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to a fire alarm being activated. There was no fire or smoke and the alarm was reset.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 09/12/2022	<b>Time Reported:</b> 10:04 PM
<b>Date(s) Occurred:</b> 09/12/2022	<b>Time(s) Occurred:</b> 10:04 PM
<b>Location:</b> Margaret Nance Hall	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to a smoke alarm in room 126. No smoke or fire was observed and the alarm was reset.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 09/15/2022	<b>Time Reported:</b> 12:05 AM
<b>Date(s) Occurred:</b> 09/15/2022	<b>Time(s) Occurred:</b> 12:05 AM
<b>Location:</b> Lee Wicker Hall	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to a smoke alarm activation. The officer met with the subject who stated that he took a long shower and when he got out the alarm started to sound. The alarm was reset.	
<b>Disposition:</b> Complete	





**Winthrop University  
Police Department**

**Daily Fire Log**

Month of September, 2022



<b>Incident #:</b> N/A	
<b>Date Reported:</b> 09/16/2022	<b>Time Reported:</b> 3:08 PM
<b>Date(s) Occurred:</b> 09/16/2022	<b>Time(s) Occurred:</b> 3:08 PM
<b>Location:</b> W. Thomson Hall	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded to room 242 in reference to a fire alarm being activated. The alarm was set off from steam from the shower. The alarm was reset.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 09/18/2022	<b>Time Reported:</b> 8:39 PM
<b>Date(s) Occurred:</b> 09/18/2022	<b>Time(s) Occurred:</b> 8:39 PM
<b>Location:</b> Tillman Hall	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to a fire alarm being activated. A walkthrough was conducted and there was no fire or smoke and the alarm was reset.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 09/19/2022	<b>Time Reported:</b> 7:50 PM
<b>Date(s) Occurred:</b> 09/19/2022	<b>Time(s) Occurred:</b> 7:50 PM
<b>Location:</b> Tillman Hall	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to a fire alarm. The area was checked with no issues. While there an alarm came in at the DiGiorgio Campus Center and Mybryde. All of the areas were checked with no issues and the alarms were reset.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 09/26/2022	<b>Time Reported:</b> 4:24 AM
<b>Date(s) Occurred:</b> 09/26/2022	<b>Time(s) Occurred:</b> 4:24 AM
<b>Location:</b> Margaret Nance Hall	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded but did not see any fire or smoke. The alarm was reset.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 09/28/2022	<b>Time Reported:</b> 9:55 PM
<b>Date(s) Occurred:</b> 09/28/2022	<b>Time(s) Occurred:</b> 9:55 PM
<b>Location:</b> Lee Wicker Hall	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to a fire alarm in 110. The officer did not observe and smoke or fire in the room and the alarm was reset. The officer also observed the resident holding a nerf gun which is against policy and confiscated the nerf gun.	
<b>Disposition:</b> Complete	



Winthrop University  
Police Department



Daily Fire Log

Month of September, 2022

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 09/30/2022	<b>Time Reported:</b> 7:50 PM
<b>Date(s) Occurred:</b> 09/30/2022	<b>Time(s) Occurred:</b> 7:50 PM
<b>Location:</b> Phelps Hall	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to the fire alarm in room 380. The officer was unable to detect any smoke or fire. One of the residents stated she had used a vape earlier and maybe it caused the alarm to sound. The alarm was reset.	
<b>Disposition:</b> Complete	

<b>Incident #:</b>	
<b>Date Reported:</b>	<b>Time Reported:</b>
<b>Date(s) Occurred:</b>	<b>Time(s) Occurred:</b>
<b>Location:</b>	
<b>Incident Type:</b>	
<b>Synopsis:</b>	
<b>Disposition:</b>	

<b>Incident #:</b>	
<b>Date Reported:</b>	<b>Time Reported:</b>
<b>Date(s) Occurred:</b>	<b>Time(s) Occurred:</b>
<b>Location:</b>	
<b>Incident Type:</b>	
<b>Synopsis:</b>	
<b>Disposition:</b>	



**Winthrop University  
Police Department**

**Daily Fire Log**

Month of October, 2022



<b>Incident #:</b> N/A	
<b>Date Reported:</b> 10/01/2022	<b>Time Reported:</b> 7:15 PM
<b>Date(s) Occurred:</b> 10/01/2022	<b>Time(s) Occurred:</b> 7:15 PM
<b>Location:</b> Margaret Nance Hall	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to the fire alarm being activated in room 219. The subject stated she had lit an incense inside her room and the alarm went off. The alarm was reset and the subject will be referred to the Dean's office.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 10/12/2022	<b>Time Reported:</b> 3:02 PM
<b>Date(s) Occurred:</b> 10/12/2022	<b>Time(s) Occurred:</b> 3:02 PM
<b>Location:</b> Margaret Nance Hall	
<b>Incident Type:</b> Fire Alarm Activation – Fire Drill	
<b>Synopsis:</b> The officer reported and conducted a fire drill.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 10/22/2022	<b>Time Reported:</b> 9:54 PM
<b>Date(s) Occurred:</b> 10/21/2022	<b>Time(s) Occurred:</b> 9:54 PM
<b>Location:</b> Margaret Nance Hall	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to a fire alarm on the third floor. A student burnt food while cooking which caused the alarm to go off. The alarm was reset.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 10/29/2022	<b>Time Reported:</b> 12:31 AM
<b>Date(s) Occurred:</b> 10/29/2022	<b>Time(s) Occurred:</b> 12:31 AM
<b>Location:</b> Phelps Hall	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to a fire alarm and there was a large amount of smoke coming from 322. The subject stated he was warming up a sandwich which was in foil wrap causing it to smoke. RHFDD was able to ventilate and clear the smoke out.	
<b>Disposition:</b> Complete	

<b>Incident #:</b>	
<b>Date Reported:</b>	<b>Time Reported:</b>
<b>Date(s) Occurred:</b>	<b>Time(s) Occurred:</b>
<b>Location:</b>	
<b>Incident Type:</b>	
<b>Synopsis:</b>	
<b>Disposition:</b>	



**Winthrop University  
Police Department**

**Daily Fire Log**

Month of November, 2022



<b>Incident #:</b> N/A	
<b>Date Reported:</b> 11/02/2022	<b>Time Reported:</b> 4:27 PM
<b>Date(s) Occurred:</b> 11/02/2022	<b>Time(s) Occurred:</b> 4:27 PM
<b>Location:</b> Phelps Hall	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to smoke alarm in room 73. The alarm was actually coming from room 71 and there was no fire or smoke. The alarm was reset.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 11/06/2022	<b>Time Reported:</b> 6:52 PM
<b>Date(s) Occurred:</b> 11/06/2022	<b>Time(s) Occurred:</b> 6:52 PM
<b>Location:</b> Lee Wicker Hall	
<b>Incident Type:</b> Other – Fire Alarm	
<b>Synopsis:</b> The officer responded in reference to the fire alarm. There was an odor of burnt popcorn in the room and the alarm was reset.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 11/07/2022	<b>Time Reported:</b> 5:24 PM
<b>Date(s) Occurred:</b> 11/07/2022	<b>Time(s) Occurred:</b> 5:24 PM
<b>Location:</b> Phelps Hall	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to an alarm activated in room 264. There was no fire or smoke and the alarm was reset.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 11/12/2022	<b>Time Reported:</b> 10:29 PM
<b>Date(s) Occurred:</b> 11/12/2022	<b>Time(s) Occurred:</b> 10:29 PM
<b>Location:</b> Margaret Nance Hall	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to a fire alarm being activated. The subject was heating food in the microwave which triggered the smoke alarm.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 11/21/2022	<b>Time Reported:</b> 7:37 PM
<b>Date(s) Occurred:</b> 11/21/2022	<b>Time(s) Occurred:</b> 7:37 PM
<b>Location:</b> Phelps Hall	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to a smoke alarm being activated. The subjects stated they were eating when it went off randomly. The alarm was reset.	
<b>Disposition:</b> Complete	



Winthrop University  
Police Department



Daily Fire Log

Month of November, 2022

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 11/29/2022	<b>Time Reported:</b> 8:55 AM
<b>Date(s) Occurred:</b> 11/29/2022	<b>Time(s) Occurred:</b> 8:55 AM
<b>Location:</b> Margaret Nance Hall	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to a fire alarm. The officer spoke with the subject who stated she was spraying a pair of jeans with a wrinkle release when the detector went off. The alarm was reset.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 11/30/2022	<b>Time Reported:</b> 11:03 PM
<b>Date(s) Occurred:</b> 11/30/2022	<b>Time(s) Occurred:</b> 11:03 PM
<b>Location:</b> Lee Wicker Hall	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded to a fire alarm in room 256. The resident stated the alarm just started going off for no apparent reason. There were no issues and the alarm was reset.	
<b>Disposition:</b> Complete	



**Winthrop University  
Police Department**

**Daily Fire Log**

Month of December, 2022



<b>Incident #:</b> N/A	
<b>Date Reported:</b> 12/01/2022	<b>Time Reported:</b> 8:08 PM
<b>Date(s) Occurred:</b> 12/01/2022	<b>Time(s) Occurred:</b> 8:08 PM
<b>Location:</b> Phelps Hall	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded and went to room 67 which is where the alarm was and found the steam from a hair dryer had caused the alarm to sound. The alarm was reset.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 12/03/2022	<b>Time Reported:</b> 1:40 PM
<b>Date(s) Occurred:</b> 12/03/2022	<b>Time(s) Occurred:</b> 1:40 PM
<b>Location:</b> Phelps Hall	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to the alarm and found it was caused by burnt food. The alarm was reset.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 12/03/2022	<b>Time Reported:</b> 10:11 PM
<b>Date(s) Occurred:</b> 12/03/2022	<b>Time(s) Occurred:</b> 10:11 PM
<b>Location:</b> Phelps Hall	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded to the common area and in reference to a fire alarm and observed burnt muffins. The alarm was reset.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 12/25/2022	<b>Time Reported:</b> 10:55 AM
<b>Date(s) Occurred:</b> 12/25/2022	<b>Time(s) Occurred:</b> 10:55 AM
<b>Location:</b> McLaurin Hall	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to a water flow alarm due to a water leak. FM responded to the scene.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 12/25/2022	<b>Time Reported:</b> 3:00 PM
<b>Date(s) Occurred:</b> 12/25/2022	<b>Time(s) Occurred:</b> 3:00 PM
<b>Location:</b> The Courtyard	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to an alarm due to a water flow alarm. FM responded to the scene.	
<b>Disposition:</b> Complete	



**Winthrop University  
Police Department**

**Daily Fire Log**

Month of December, 2022



<b>Incident #:</b> N/A	
<b>Date Reported:</b> 12/25/2022	<b>Time Reported:</b> 3:57 PM
<b>Date(s) Occurred:</b> 12/25/2022	<b>Time(s) Occurred:</b> 3:57 PM
<b>Location:</b> McLaurin Hall	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to an alarm due to a water flow alarm. FM responded to the scene.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 12/26/2022	<b>Time Reported:</b> 3:27 AM
<b>Date(s) Occurred:</b> 12/26/2022	<b>Time(s) Occurred:</b> 3:27 AM
<b>Location:</b> The Courtyard	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference a fire alarm in a room and there was large amounts of water on the floor. FM responded to the scene.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 12/26/2022	<b>Time Reported:</b> 10:13 PM
<b>Date(s) Occurred:</b> 12/26/2022	<b>Time(s) Occurred:</b> 10:13 PM
<b>Location:</b> The Courtyard	
<b>Incident Type:</b> Fire Alar Activation	
<b>Synopsis:</b> The officer responded in reference to a fire alarm. The officer could not get the alarm to reset and FM responded.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 12/27/2022	<b>Time Reported:</b> 4:23 AM
<b>Date(s) Occurred:</b> 12/27/2022	<b>Time(s) Occurred:</b> 4:23 AM
<b>Location:</b> Rutledge Building	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to a fire alarm. The officer attempted to reset the alarm but was unable to. FM responded.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 12/27/2022	<b>Time Reported:</b> 6:37 AM
<b>Date(s) Occurred:</b> 12/27/2022	<b>Time(s) Occurred:</b> 6:37 AM
<b>Location:</b> McLaurin Hall	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to a water flow alarm. FM responded to the scene.	
<b>Disposition:</b> Complete	



Winthrop University  
Police Department



Daily Fire Log

Month of December, 2022

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 12/28/2022	<b>Time Reported:</b> 12:50 AM
<b>Date(s) Occurred:</b> 12/28/2022	<b>Time(s) Occurred:</b> 12:50 AM
<b>Location:</b> Rutledge Building	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to a fire alarm. The officer attempted to reset the alarm but was unable to. FM responded.	
<b>Disposition:</b> Complete	

<b>Incident #:</b> N/A	
<b>Date Reported:</b> 12/28/2022	<b>Time Reported:</b> 10:59 PM
<b>Date(s) Occurred:</b> 12/28/2022	<b>Time(s) Occurred:</b> 10:59 PM
<b>Location:</b> The Courtyard	
<b>Incident Type:</b> Fire Alarm Activation	
<b>Synopsis:</b> The officer responded in reference to a fire alarm. The officer attempted to reset the alarm but was unable to reset the alarm. FM responded.	
<b>Disposition:</b> Complete	

<b>Incident #:</b>	
<b>Date Reported:</b>	<b>Time Reported:</b>
<b>Date(s) Occurred:</b>	<b>Time(s) Occurred:</b>
<b>Location:</b>	
<b>Incident Type:</b>	
<b>Synopsis:</b>	
<b>Disposition:</b>	

<b>Incident #:</b>	
<b>Date Reported:</b>	<b>Time Reported:</b>
<b>Date(s) Occurred:</b>	<b>Time(s) Occurred:</b>
<b>Location:</b>	
<b>Incident Type:</b>	
<b>Synopsis:</b>	
<b>Disposition:</b>	